

CERTIFICATE

This is to certify that we had carried-out complete inspected internally and externally to Fire Extinguisher and certificate issue to :-

M/s:- THE GREEN WORLD INTERNATIONAL SCHOOL

Add:- JHALIRIYA (M.P)

Testing & Inspection Report of fire Extinguisher

Year of Contract	2026-2027	
Certificate No.	AFPS/IND	
Completion Month	30 /08/ 2026	
Valid Up to	29 /08 /2027	
Warranty for	01 Year	
Details of New /Refilling Extinguisher	ABC Type Fire Extinguisher Cap.4.0 Kg	Qty.09
	CO2 Type Fire Extinguisher Cap.4.5 Kg	Qty.01
	Total Quantity	Qty.10
Inspection Details Of fire Extinguisher	1. Check for proper sizes,types, quantity and placement of fire extinguisher. ensure that each fire extinguisher is properly mounted conspicuously located not obstructed by objects and readily available for use in case of a fire . 2. Make sure the instruction label is legible and facing outward. 3. Check to be sure the extinguisher is fully pressurized and /or at its full charged weight . Make sure the fire extinguisher hose is intact and free from obstruction. 4. Operate the pull pin or locking device and install a new tamper seal. Check for dents corrosion or other signs of damage. 5. Look for any modifications to the fire extinguisher that could possibly reduce its functionality 6. Verify that the extinguisher is current on all internal maintenance and pressure testing requirements. 7. Attach an updated tag or label as a record of proper maintenance .	

Declaration	We further certify that (Aditya Fire Protection) has successfully checked above fire extinguisher which is in good & working condition but necessary periodical maintenance, services and 'efill when required to fire extinguisher will be dore by us.
Note :-	The Guarantee of Pressure Remains 3 Days From The Refilling Date even if The Yellow seal is Installed.

inspector

Signature of the



